



# ENVIKIT CHLORINE

ENVIKIT 08CI  
From 0,02 mg/l – 100 tests



- Thank you for choosing products of Binh Lan ENVIBIOCHEM. Please read instruction carefully before proceeding to ensure accurate results.
- Reagents contain acid. In case of contact, immediately flush skin with plenty of water.



1. Fill the tube half with sample water.



2. Add 2 drops of the Reagent and invert to mix.



3. Place the tube on a white paper. The pink color is indication of chlorine.

Wash all items by clean water, leave to dry in the air, and store in the box for the next test.

## BINH LAN ENVIBIOCHEM COMPANY Limited

Web: <http://www.binhlan.com> Email: [binhlanbiochem@gmail.com](mailto:binhlanbiochem@gmail.com)

Office 1: Science-Technology Business Incubator of HoChiMinh City  
268 Ly Thuong Kiet Street, District 10, HoChiMinh City, Vietnam

Office 2: 595/208A Cach mang thang 8, Ward 15, District 10, HoChiMinh, Vietnam

Tel: 08-39700106, **Hotline:** 0985714580

For technical support, quotation and order  
Email to [binhlanbiochem@gmail.com](mailto:binhlanbiochem@gmail.com)